



Contact: Michelle Wittholz
Telephone: 8226 7105
Email: michelle.wittholz@sa.gov.au

Public Health Services
Citi Centre Building
11 Hindmarsh Square
Adelaide SA 5000
PO Box 6
Rundle Mall SA 5000
DX 243
Tel 08 8226 7100
Fax 08 8226 7102
ABN 97 643 356 590
www.health.sa.gov.au

Our reference: WWP-20033

Attn: Owen Luke
Reln Pty Ltd
PO Box 5182
Minto BC NSW 2566


Dear Owen,

**RE: PRODUCT APPROVAL FOR THE RELN 3200L SEPTIC/HOLDING TANK WITH RISER,
RELN 4000L SEPTIC/HOLDING TANK WITH RISER AND RELN 450/600 PUMP SUMP**

I refer to your application seeking approval for the above products. I advise that, pursuant to South Australian Public Health (Wastewater) Regulations 2013, an approval is issued for marketing, sale and installation of this product in South Australia, subject to the following conditions:

1. The approved system incorporates:
 - 1.1. Reln 3200L septic/holding tank.
 - 1.1.1. Tapered cylindrical tank, injection moulded polypropylene, with height 2038mm and top width 1998mm.
 - 1.1.2. Septic tank has an internal baffle with ration 2:1.
 - 1.1.3. Maximum of one 385mm riser to be fitted with reinforced brace ring.
 - 1.2. Reln 4000L septic/holding tank.
 - 1.2.1. Tapered cylindrical tank, injection moulded polypropylene, with height 2408mm and top width 1998mm.
 - 1.2.2. Septic tank has an internal baffle with ration 2:1.
 - 1.2.3. Maximum of one 385mm riser to be fitted with reinforced brace ring.
 - 1.3. Reln 450/600 Pump well
 - 1.3.1. Injection moulded polypropylene with height 1300mm and width 1400mm.
 - 1.3.2. Pump well includes 125mm wide anchoring flange and has anchoring points.
2. The system is to be installed, commissioned, operated and maintained in accordance with:
 - 2.1. The plans and specifications as submitted.
 - 2.2. The manufacturer and/or equipment suppliers' instructions and recommendations.
 - 2.3. All relevant standards and codes.
 - 2.4. Conditions of this approval.

3. The manufacturer shall provide the following information to the owner of the premises at which the system is installed:
 - 3.1. Copies of the Installation Manual for the system.
 - 3.2. A copy of any additional SA Department for Health and Ageing guidelines and requirements including a copy of the section of this approval titled 'Installation, operation and maintenance requirements of the Reln 3200L septic/holding tank with riser, RELN 4000L septic/holding tank with riser and RELN 450/600 pump sump
 - 3.3. Instructions informing persons installing, operating and or maintaining the septic tank of their obligations with regard to the 'Confined Space' requirements pursuant to the Work Health and Safety Regulations 2012.
4. Other requirements for the approved product are as follows:
 - 4.1. Lids and access openings are to be fitted so as to be childproof.
 - 4.2. Where any increment risers are required, they must be a type approved by the Minister of Health for use with this unit
5. The DHA reserves the right to conduct an inspection on a completed unit to establish compliance with the submitted plans and the conditions of this approval.
6. Modification of the design of the system or any of its associated components requires approval by the DHA.
7. Each individual installation of a system is to be subject to an application to the relevant authority for assessment of prevailing site conditions and its approval for installation at the site. The approval may include additional requirements relevant to the site.
8. This approval is not to be used for any advertising purposes and is not transferable.
9. Pursuant to the South Australia Public Health (Wastewater) Regulations 2013, an approval is granted for a period of five years from the date of this approval. This approval will lapse unless renewed by the submission of an application and grant of an approval from the DHA prior to the expiry date.

Approved by:  (Michelle Wittholz) Date: 27 April 2018

Manager, Wastewater Management Section
Delegate of the Minister for Health and Ageing

- References:**
- **Specification documents and Engineered drawings for Reln 3200L and 4000L septic/holding tanks and risers, dated 14/8/2010**
 - **Product certification against 1546.1 issued by Approvalmark, Certificate no: AMI 1651**
 - **Reln Blackwater products Septic Tank and holding tank installation Guide, provided with this application**
 - **Reln Pump well installation instruction, provided with this application**

Please note that this approval will expire on 27 April 2023. If the product is not reassessed and reapproved before this date, it may be removed from the SA Health approved product database without notification.

INSTALLATION OPERATION AND MAINTENANCE REQUIREMENTS OF THE RELN 3200L SEPTIC/HOLDING TANK WITH RISER, RELN 4000L SEPTIC/HOLDING TANK WITH RISER AND RELN 450/600 PUMP SUMP

- Note 1.** All installations of the Reln 3200L septic/holding tank with riser, Reln 4000L septic/holding tank with riser and Reln 450/600 pump sump are to be subject to individual application and fee to the relevant approving authority for assessment of prevailing site conditions to determine the system installation requirements in addition to the requirements of this approval. The relevant authority reserves the right to require further testing and/or information to be carried out/supplied in order to assess an application of this nature.
- Note 2.** A licensed plumber must carry out the installation of the system. Installation must be in accordance with AS/NZS 3500, the product and installation approval conditions, manufacturers' requirements and any other specific requirements by the relevant authority.
- Note 3.** The system, once installed, must be maintained in a fully operational and sanitary state at all times by the user/owner of the system in accordance with the product and installation approval conditions, manufacturers' requirements and any other specific requirements by the relevant authority.
- Note 4.** Vehicular traffic is to be excluded from the area around the unit and the effluent disposal site.
- Note 5.** The relevant authority reserves the right to exclude connection of this product to a Community Wastewater Management System.